

ELECTRICAL INSTALLATION CONDITION

REPORT
Requirements For Electrical Installations - BS 7671 23650240

1 DET	AILS OF 1	HE PER	SON ORI	DERING	THE	E REPOI	RT					
Client:	Condor P	roperties										
Address:	Mill Hous	e, Lugg Br	idge Mill, I	Hereford,	, HR1	3NA						
2/REA	SON FOR	PRODUC	CING TH	IS REPO	ORT							
	or producing											
Landlords	safety repo	rt.										
Date on wh	ich inspection	n and testin	g was carri	ed out:		12/07	//2024					
3 DET	AILS OF 1	THE INS	FALLATI	ON WH	ICH	IS THE	SUBJEC	T OF	THIS	REPOR	T	
Installatio	on Address:	Ground F	loor Flat, 1	.14 Miski	in Stre	eet, Cath	ays, Cardif	ff, CF2	4 4AS			
Description	of premises:	Domestic	N/A	Commer	rcial	√ In	ndustrial	N/A	Other:		N/A	4
Estimated a	age of wiring	system:	15 yea	ars		vidence of terations:	additions/	N	o if ye	es, estima	ated age:	N/A years
Installation	records avail	lable? (Reg	ulation 651	.1)	Yes	lterations.		Date	of last ir	nspection:	: 0	8/07/2021
4/EXT	ENT AND	LIMITA	TIONS O	F INSPI	ECTI	ON ANI	TESTI	NG				
	the electrica	l installatio	າ covered b	y this rep	ort:							
Ground F	oor Flat											
	tations includ					2):						
_	of floor boa		•									
Inspection	n Concealed	Cables Co	ntained w	ithin The	Fabri	ic Of The	Installatio	n.				
Agreed with	ո:	Condor	Properties									
Operational	limitations in	ncluding the	reasons:									
None												
	ion and testin					nying sch	edules hav	e been	carried	out in acc	cordance	with BS
It should be	IET Wiring I noted that o	cables conc	ealed withir	trunking	and c	conduits, u	nder floors	s, in ro	of space	s, and ge	nerally w	ithin the fabric
	ing or undero An inspectior											prior to the
	<u> </u>							other e	lectrical	ечиртне		
- /	IMARY OF on 8 for a su							of aloc	trical ca	foty		
	sessment of	•	•					or elec	li icai sa	,		
continued		tile ilista	nation in t	erilis or i	11 5 50	псартту	101	L		SATISF	ACTORY	
	tisfactory as have been			that dan	gerou	us (Code	C1) and/o	or pote	entially	dangero	ous (Cod	e C2)
6/REC	OMMEND	ATIONS										
												ISFACTORY',
	imend that ai of urgency.	ny observat	ions classifi	ied as 'Co	de 1 -	Danger P	resent' or '	'Code 2	? - Poter	itially dan	igerous' a	re acted upon
Investigation	n without de										red'.	
	ns classified a the necessary		·				-	uue COI	isiuerat			
the installa	tion is further	inspected	and tested	by:							ears	
	proposed date can reasonal											nance that the

7 /0B	SERVATIONS AND RECOMMENDAT	TIONS FOR ACTIONS TO BE TAKEN	
Referri	ng to the attached schedules of inspection eport under 'Extent of the Installation and	n and test results, and subject to the limitations spe Limitations of Inspection and Testing':	cified on page 1
N/A Th	nere are no items adversely affecting electrical	safety or	
√ Th	ne following observations and recommendations		
Item No		Observations	Classification Code
1	No AFDD devices installed throughout the	e installation	C3
2	No SPD Device present		C3
3	Inspection Schedule Item 5.6: Condition o 421.1.201; 526.5) is recommended for im	f enclosure(s) in terms of fire rating etc (421.1.6; provement. (Non Metallic Construction)	С3
			i
	e following codes, as appropriate, has been allo le for the installation the degree of urgency for	ocated to each of the observations made above to indicate remedial action.	e to the person(s)
C1 Dan	ger Present of injury. Immediate edial action required C2 Potentially day Urgent remedial required		nvestigation without delay
Immedia	ate remedial action required for items:	N/A	
Urgent r	emedial action required for items:	N/A	
Improve	ment recommended for items:	1, 2, 3	
Further i	nvestigation required for items:	N/A	

Ref: 23650240 - Page: 2 of 10

						INSTAL s of electric											
		on & Fit f		•			car sarc										
9/D	FCI AR	RATION															
I/We, signatur inspection provides	being these belowed and to an and to an accuracy.	ne person v), partico esting, he	(s) res ulars of ereby d essmer	f which a declare t	are des hat the	cribed abo information	ve, hav on in th	ing exer is report	the electrical in cised reasonable , including the o ation taking into	e skill and ca bservations	re when car and the atta	rying out thiched sched	lules,				
Trading	Title:	Condo	r Prope	erties													
Address	:	Mill Ho Lugg Bı		Mill					Registratio	on Number ble):							
		Herefo	rd						Telephone	Number:	014323	367276					
						Postcode	: HR	1 3NA									
For the		-		NG AND	ASSES	SSMENT o	f the r	eport:	Signature:								
Name:		Alun Da		Po	Es D	ate: 12/07	7/2024										
		ed and a								//			- /				
Name:		Alun Da	vies	Po	osition:	: Ele	ectricia	an	Signature:	MoLinu	Žes D.	ate: 12/07	7/2024				
l 7		CHAR	ACTE	RISTI	CS A	ND EAR	THIN	G ARR	ANGEMENT	S							
/ Earth	ning		_					NI-4-		1	C	Supply Protective Device					
Arrange	ements	N			e or Liv	e Conducto	rs	Nati	ire of Supply Pai	rameters	Supply P						
TN-S:	N/A	AC:	/ (2	and Type -phase 2-wire): -phase	✓	2-phase (3-wire): 3-phase	N/A	Nomina U/Uo:	al voltage,	230 V	BS (EN):	1361					
	N/A		/ (2 3-	-phase 2-wire):	√ N/A	2-phase (3-wire):		Nomina U/Uo: Nomina	al voltage,								
TN-S:	N/A	AC: ,	(2 3- (3	-phase 2-wire): -phase	√ N/A N/A	2-phase (3-wire): 3-phase (4-wire): 3-wire:	N/A	Nomina U/Uo: Nomina Prospec	al voltage, al frequency, f: ctive fault f, lpf:	230 V	BS (EN):	1361	L				
TN-S:	N/A N/A N/A	AC: NOther:	1- (2 3- (3 1/A 2-	-phase 2-wire): -phase 3-wire): -wire:	N/A N/A N/A	2-phase (3-wire): 3-phase (4-wire): 3-wire:	N/A N/A	Nomina U/Uo: Nomina Prospec current Externa	al voltage, al frequency, f:	230 V 50 Hz	BS (EN): Type:	1361	L				
TN-S: TN-C-S: TNC:	N/A ✓ N/A	AC: NOther:	1- (2 3- (3 1/A 2-	-phase 2-wire): -phase 3-wire):	N/A N/A N/A	2-phase (3-wire): 3-phase (4-wire): 3-wire:	N/A N/A	Nomina U/Uo: Nomina Prospec current Externa loop im	al voltage, al frequency, f: ctive fault f, lpf: al earth fault	230 V 50 Hz 1.9 kA	BS (EN): Type:	1361	L				
TN-S: TN-C-S: TNC: TT: IT: IT: Means	N/A N/A N/A N/A ARTIC of Earth	AC: DC: N Other: Confirm	1- (2 3- (3 1/A 2-	-phase 2-wire): -phase 3-wire): -wire:	N/A N/A N/A	2-phase (3-wire): 3-phase (4-wire): 3-wire:	N/A N/A N/A ✓	Nomina U/Uo: Nomina Prospec current Externa loop im Numbe	al voltage, al frequency, f: ctive fault fi, lpf: al earth fault pedance, Ze:	230 V 50 Hz 1.9 kA 0.11 Ω 1	BS (EN): Type: Rated curre	1361	L				
TN-S: TN-C-S: TNC: TT: IT: IT: Means Distribut	N/A N/A N/A N/A ARTIC of Earth	AC: DC: N Other: Confirm	1- (2 3- (3 1/A 2-	-phase 2-wire): -phase 3-wire): -wire:	N/A N/A N/A	2-phase (3-wire): 3-phase (4-wire): 3-wire:	N/A N/A N/A ✓	Nomina U/Uo: Nomina Prospec current Externa loop im Numbe	al voltage, al frequency, f: ctive fault f, lpf: al earth fault pedance, Ze: r of supplies: IN THE REP th Electrode (wh	230 V 50 Hz 1.9 kA 0.11 Ω 1	BS (EN): Type: Rated curre	1361	L				
TN-S: TN-C-S: TNC: TT: IT: IT: Means	N/A N/A N/A N/A ARTIC of Earth tor's	AC: NOTHER CONFIRM CON	1-(2 3-(3 1/A 2-	-phase 2-wire): -phase 3-wire): -wire:	N/A N/A N/A r polarit	2-phase (3-wire): 3-phase (4-wire): 3-wire: A ty: ION REF Details of	N/A N/A N/A ✓	Nomina U/Uo: Nomina Prospec current Externa loop im Numbe ED TO ation Ear Locati Metho	al voltage, al frequency, f: ctive fault c, lpf: al earth fault pedance, Ze: r of supplies: IN THE REP th Electrode (when it is the content of the content	230 V 50 Hz 1.9 kA 0.11 Ω 1	BS (EN): Type: Rated curre	1361	L				
TN-S: TN-C-S: TNC: TT: IT: It	N/A N/A N/A ARTIC of Earth tor's cion ectrode:	AC: DC: N Other: Confirm ULARS	1-(2 3-(3 1/A 2-	-phase 2-wire): -phase 3-wire): -wire: of supply INSTA	N/A N/A N/A r polarit	2-phase (3-wire): 3-phase (4-wire): 3-wire: A ty: ION REF Details of N/A arth: N	N/A N/A N/A FERRE	Nomina U/Uo: Nomina Prospec current Externa loop im Numbe ED TO ation Ear Locati Metho	al voltage, al frequency, f: ctive fault c, lpf: al earth fault pedance, Ze: r of supplies: IN THE REP th Electrode (when on:	230 V 50 Hz 1.9 kA 0.11 Ω 1	BS (EN): Type: Rated curre	1361	L				
TN-S: TN-C-S: TNC: TT: IT: It	N/A N/A N/A N/A ARTIC of Earth tor's cion ectrode:	AC: DC: N Other: Confirm CULARS ing N/A vitch-Fuse	1-(2 3-(3 1/A 2- 1 action of TA R	-phase 2-wire): -phase 3-wire): -wire: of supply INSTA	N/A N/A N/A polarit	2-phase (3-wire): 3-phase (4-wire): 3-wire: A ty: ION REF Details of N/A arth: N	N/A N/A N/A FERRE	Nomina U/Uo: Nomina Prospec current Externa loop im Numbe ED TO ation Ear Locati Metho	al voltage, al frequency, f: ctive fault c, lpf: al earth fault pedance, Ze: r of supplies: IN THE REP th Electrode (when on: od of urement:	230 V 50 Hz 1.9 kA 0.11 Ω 1 ORT here applicab	BS (EN): Type: Rated curre	1361 2 ent: 100	L				
TN-S: TN-C-S: TNC: TT: IT: IT: Installate earth elements with the lements	N/A N/A N/A N/A ARTIC of Earth tor's cion ectrode:	AC: DC: N Other: Confirm CULARS ing N/A vitch-Fuse	1-(2) 3-(3) 1/A 2- 1/A 2- 1/A R 1/A R 1/A Circle / Circle	-phase 2-wire): -phase 3-wire): -wire: of supply INSTA Type: Resistance cuit-Bread upboarce	N/A N/A N/A polarit LLAT: te to Ea ker / R d Grou	2-phase (3-wire): 3-phase (4-wire): 3-wire: A ty: ION REF Details of N/A arth: N	N/A N/A N/A FERRE Install	Nomina U/Uo: Nomina Prospec current Externa loop im Numbe D TO ation Ear Locati Methor measo BS (EN	al voltage, al frequency, f: ctive fault c, lpf: al earth fault pedance, Ze: r of supplies: IN THE REP th Electrode (when on: od of urement:	230 V 50 Hz 1.9 kA 0.11 Ω 1 ORT nere applicab	BS (EN): Type: Rated curre	1361 2 ent: 100	D A				
TN-S: TN-C-S: TNC: TT: IT: It	N/A N/A N/A N/A ARTIC of Earth tor's cion ectrode: itch / Sv	AC: DC: N Other: Confirm VILARS ing Vitch-Fuse Electr 100	1-(2) 3-(3) 1/A 2- 1/A 2- 1/A R R Circal Cu	-phase 2-wire): -phase 3-wire): -wire: of supply INSTA Type: Resistance upboard -use/dev	N/A N/A N/A r polarii LLAT: ker / R d Grou ice ratii	2-phase (3-wire): 3-phase (4-wire): 3-wire: A ty: ION REF Details of N/A arth: N CD nd Floor ng or setting the setting of t	N/A N/A N/A FERRE Install	Nomina U/Uo: Nomina Prospec current Externa loop im Numbe ED TO ation Ear Locati Methor measu BS (EN N/A	al voltage, al frequency, f: ctive fault c, lpf: al earth fault depedance, Ze: r of supplies: IN THE REP th Electrode (whom: ad of curement:): 60947-3 Is A Voltage ra	230 V 50 Hz 1.9 kA 0.11 Ω 1 ORT nere applicab	BS (EN): Type: Rated curre N/A N/A Number of	1361 2 ent: 100	D A				
TN-S: TN-C-S: TNC: TT: IT: IT: IT: Means Distribut facility: Installat earth ele Main Sw Location Current	N/A N/A N/A N/A ARTIC of Earth tor's cion ectrode: itch / Sw rating: main swit	AC: DC: N Other: Confirm VILARS ing Vitch-Fuse Electr 100	1-(2) 3-(3) 1/A 2- 1 TA R 1 Circlical Cu	-phase 2-wire): -phase 3-wire): -wire: of supply INSTA Type: Resistance upboard -use/dev	N/A N/A N/A r polarii LLAT: LLAT: de to Eacher / R de Groundice ratii	2-phase (3-wire): 3-phase (4-wire): 3-wire: A ty: ION REF Details of N/A arth: N CD nd Floor	N/A N/A N/A FERRE Install	Nomina U/Uo: Nomina Prospec current Externa loop im Numbe ED TO ation Ear Locati Methor measu BS (EN N/A	al voltage, al frequency, f: ctive fault fi, lpf: al earth fault pedance, Ze: r of supplies: IN THE REP th Electrode (where the continuous of the continuou	230 V 50 Hz 1.9 kA 0.11 Ω 1 ORT nere applicab	BS (EN): Type: Rated curre N/A N/A Number of	1361 2 ent: 100	D A				
TN-S: TN-C-S: TNC: TT: IT: It	N/A N/A N/A N/A ARTIC of Earth tor's cion ectrode: itch / Sw n: rating: nain swit	AC: DC: N Other: Confirm Vitch-Fuse Electr 100	1-(2) 3-(3) I/A 2- Ination of SOF I TA R A F R C	-phase 2-wire): -phase 3-wire): -wire: of supply INSTA Type: Resistance upboard Fuse/dev Rated rescurrent (I	N/A N/A N/A r polarit LLAT: te to Eaker / R d Grout ice ratii sidual c lan):	2-phase (3-wire): 3-phase (4-wire): 3-wire: A ty: ION REF Details of N/A arth: N CD nd Floor ng or setting perating	N/A N/A N/A N/A FERRE Install I/A Ω N/A	Nomina U/Uo: Nomina Prospec current Externa loop im Numbe ED TO ation Ear Locati Method measu BS (EN N/A	al voltage, al frequency, f: ctive fault c, lpf: al earth fault depedance, Ze: r of supplies: IN THE REP th Electrode (whom: od of curement:): 60947-3 Is A Voltage ra Rated time	230 V 50 Hz 1.9 kA 0.11 Ω 1 ORT here applicab solator ting: 23	BS (EN): Type: Rated curre N/A N/A Number of Measured operating ti	1361 2 ent: 100	D A				
TN-S: TN-C-S: TNC: TT: IT: IT: IT: IT: IT: IT: IT: IT: IT	N/A N/A N/A N/A N/A ARTIC of Earth tor's cion ectrode: itch / Sv rating: nain switt pe:	AC: DC: N Other: Confirm VILARS ing Vitch-Fuse Electr 100 ich: N/A	1-(2) 3-(3) 1/A 2- 1 TA R 2 / Circlical Cu A F Conding	-phase 2-wire): -phase 3-wire): -phase 3-wire): -wire: Constant Conduct Conduct Conduct	N/A N/A N/A r polarit LLAT: te to Eaker / R d Grout ice ratii sidual c lan):	2-phase (3-wire): 3-phase (4-wire): 3-wire: A ty: ION REF Details of N/A arth: N CD nd Floor ng or setting perating	N/A N/A N/A N/A FERRE Install N/A N/A	Nomina U/Uo: Nomina Prospec current Externa loop im Numbe ED TO ation Ear Locati Methor measu BS (EN N/A MA	al voltage, al frequency, f: ctive fault c, lpf: al earth fault depedance, Ze: r of supplies: IN THE REP th Electrode (whom: ad of curement: A Voltage ra Rated time delay: conding of extrant of water installat	230 V 50 Hz 1.9 kA 0.11 Ω 1 ORT here applicab Solator ting: 23	BS (EN): Type: Rated curre N/A N/A Number of Measured operating ti tive parts To gas in	1361 2 ent: 100	D A				
TN-S: TN-C-S: TNC: TT: IT: IT: IT: IT: IT: IT: IT: IT: IT	N/A N/A N/A N/A N/A N/A ARTIC of Earth tor's cion ectrode: rating: rating: nain swit pe: q and Pro q conduct cor	DC: N Other: Confirm CULARS ing Vitch-Fuse Electr 100 cch: N/A	1-(2) 3-(3) 1/A 2- 1-(1)	-phase 2-wire): -phase 3-wire): -phase 3-wire): -wire: INSTA Type: Resistanc cuit-Brea upboard Fuse/dev Rated res current (I Conduct csa: 16	N/A N/A N/A N/A r polarit te to Eater / R d Grout ice rati sidual of	2-phase (3-wire): 3-phase (4-wire): 3-wire: A ty: ION REF Details of N/A arth: n cp nd Floor ng or settin perating Connectic continuit	N/A N/A N/A N/A N/A N/A N/A N/A Install I/A Ω Install I/A Ω	Nomina U/Uo: Nomina Prospec current Externa loop im Numbe ED TO: ation Ear Locati Methor measu BS (EN N/A MA	al voltage, al frequency, f: ctive fault c, lpf: al earth fault depedance, Ze: r of supplies: IN THE REP th Electrode (whom: ad of curement: A Voltage ra Rated time delay: conding of extran	230 V 50 Hz 1.9 kA 0.11 Ω 1 ORT here applicab Solator ting: 23	BS (EN): Type: Rated curre N/A N/A Number of Measured operating ti tive parts To gas in pipes: To lightni protectio	1361 2 ent: 100 poles: ime: N installation ing	2 I/A ms N/A				

Ref: 23650240 - Page: 3 of 10

14/ 1	NSPECTION SCHEDULE	
Item	Description	Outcome
1.0	EXTERNAL CONDITION OF INTAKE EQUIPMENT (VISUAL INSPECTION ONLY) Where inadequacies in intake equipment are encountered, it is recommended that the person ordering the r the appropriate authority	eport informs
1.1	Service cable	Pass
1.2	Service head	Pass
1.3	Earthing arrangements	Pass
1.4	Meter tails	Pass
1.5	Metering equipment	Pass
1.6	Isolator (where present)	Pass
2.0	PRESENCE OF ADEQUATE ARRANGEMENTS FOR PARALLEL OR SWITCHED ALTERNATIVE SOURCES	
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)	N/A
2.2	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)	N/A
3.0	AUTOMATIC DISCONNECTION OF SUPPLY	
3.1	Main earthing/bonding arrangements (411.3; Chap 54):	
3.1.1	Presence of distributor's earthing arrangement (542.1.2.1; 542.1.2.2), or presence of installation earth electrode arrangement (542.1.2.3)	Pass
3.1.2	Adequacy of earthing conductor size (542.3; 543.1.1)	Pass
3.1.3	Adequacy of earthing conductor connections (542.3.2)	Pass
3.1.4	Accessibility of earthing conductor connections (543.3.2)	Pass
3.1.5	Adequacy of main protective bonding conductor sizes (544.1)	Pass
3.1.6	Adequacy and location of main protective bonding conductor connections (543.3.2; 544.1.2)	Pass
3.1.7	Accessibility of all protective bonding connections (543.3.2)	Pass
3.1.8	Provision of earthing/bonding labels at all appropriate locations (514.13)	Pass
3.2	FELV - requirements satisfied (411.7; 411.7.1)	N/A
4.0	OTHER METHODS OF PROTECTION (where any of the methods listed below are employed details	should be
	provided on separate sheets)	
4.1	Non-conducting location (418.1)	N/A
4.2	Earth-free local equipotential bonding (418.2)	N/A
4.3	Electrical separation (Section 413; 418.3)	N/A
4.4	Double insulation (Section 412)	N/A
4.5	Reinforced insulation (Section 412)	N/A
5.0	DISTRIBUTION EQUIPMENT	
5.1	Adequacy of working space/accessibility to equipment (132.12; 513.1)	Pass
5.2	Security of fixing (134.1.1)	Pass
5.3	Condition of insulation of live parts (416.1)	Pass
5.4	Adequacy/security of barriers (416.2)	Pass
5.5	Condition of enclosure(s) in terms of IP rating etc (416.2)	Pass
5.6	Condition of enclosure(s) in terms of fire rating etc (421.1.6; 421.1.201; 526.5)	C3
5.7	Enclosure not damaged/deteriorated so as to impair safety (651.2)	Pass
5.8	Presence and effectiveness of obstacles (417.2)	Pass
5.9	Presence of main switch(es), linked where required (462.1; 462.1.201; 462.2)	Pass
5.10	Operation of main switch(es) (functional check) (643.10)	Pass
5.11	Manual operation of circuit-breakers, RCDs and AFDDs to prove functionality (643.10)	Pass
5.12	Confirmation that integral test button/switch causes RCD(s) to trip when operated (functional check) (643.10)	Pass
5.13	RCD(s) provided for fault protection – includes RCBOs (411.4.204; 411.5.2; 531.2)	N/A
5.14	RCD(s) provided for additional protection/requirements, where required – includes RCBOs (411.3.3; 415.1)	Pass
Accepta condition	ble PASS Unacceptable C1 or C2 Improvement C3 Further FI Not N/V Limitation LTM	Not pplicable N/A
	n is based on the model shown in Appendix 6 of BS 7671:2018+A2:2022. Ref: 23650240	***************************************

/	NSPECTION SCHEDULE (CONTINUED)		
Item	Description	Outcome	
5.15	Presence of RCD six-monthly test notice, where required (514.12.2)	Pass	
5.16	Presence of diagrams, charts or schedules at or near equipment, where required (514.9.1)	Pass	
5.17	Presence of alternative supply warning notice at or near equipment, where required (514.15)	Pass	
5.18	Presence of next inspection recommendation label (514.12.1)	Pass	
5.19	Presence of other required labelling (please specify) (Section 514)	N/A	
5.20	Compatibility of protective devices, bases and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.5; 411.6; Sections 432, 433)	Pass	
5.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	Pass	
5.22	Protection against mechanical damage where cables enter equipment (522.8.1; 522.8.5; 522.8.11)	Pass	
5.23	Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1)	Pass	
6.0	DISTRIBUTION CIRCUITS		
6.1	Identification of conductors (514.3.1)	Pass	
6.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	LIM	
6.3	Condition of insulation of live parts (416.1)	Pass	
6.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1)	N/A	
6.5	Suitability of containment systems for continued use (including flexible conduit) (Section 522)	Pass	
6.6	Cables correctly terminated in enclosures (Section 526)	Pass	
6.7	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)	Pass	
6.8	Examination of cables for signs of unacceptable thermal or mechanical damage/deterioration (421.1; 522.6)	Pass	
6.9	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	Pass	
6.10	Adequacy of protective devices: type and rated current for fault protection (411.3)	Pass	
6.11	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	Pass	
6.12	Coordination between conductors and overload protective devices (433.1; 533.2.1)	Pass	
6.13	Cable installation methods/practices with regard to the type and nature of installation and external influences (Section 522)	N/A	
6.14	Where exposed to direct sunlight, cable of a suitable type (522.11.1)	N/A	
6.15	Cables concealed under floors, above ceilings, in walls/partitions less than 50mm from a surface, ar partitions containing metal parts:	d in	
.15.1	Installed in prescribed zones (see Section 4. Extent and limitations) (522.6.202) or	LIM	
5.15.2	Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section 4. Extent and limitations) (522.6.204)	N/A	
6.16	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	Pass	
6.17	Band II cables segregated/separated from Band I cables (528.1)	Pass	
6.18	Cables segregated/separated from non-electrical services (528.3)	Pass	
6.19	Condition of circuit accessories (651.2)	Pass	
6.20	Suitability of circuit accessories for external influences (512.2)	Pass	
6.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	Pass	
6.22	Adequacy of connections, including cpcs, within accessories and to fixed and stationary equipment – identify/record numbers and locations of items inspected (Section 526)	Pass	
6.23	Presence, operation and correct location of appropriate devices for isolation and switching (Chapter 46; Section 537)	Pass	
	General condition of wiring systems (651.2)	Pass	
6.24			
	Temperature rating of cable insulation (522.1.1; Table 52.1)	Pass	
6.25	Temperature rating of cable insulation (522.1.1; Table 52.1) FINAL CIRCUITS	Pass	
6.25	·	Pass	
6.25 7.0	FINAL CIRCUITS		
	FINAL CIRCUITS Identification of conductors (514.3.1)	Pass	

Ref: 23650240 - Page: 5 of 10

/Item			
	Description	Outcome	
7.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1)	N/A	
7.5	Suitability of containment systems for continued use (including flexible conduit) (Section 522)	Pass	
7.6	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	Pass	
7.7	Adequacy of protective devices: type and rated current for fault protection (411.3)	Pass	
7.8	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	Pass	
7.9	Co-ordination between conductors and overload protective devices (433.1; 533.2.1)	Pass	
7.10	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)	Pass	
7.11	Cables concealed under floors, above ceilings, in walls/partitions, adequately protected against date (522.6.201; 522.6.202; 522.6.203; 522.6.204):	mage	
7.11.1	Installed in prescribed zones (see Section 4. Extent and limitations) (522.6.202)	LIM	
7.11.2	Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section 4. Extent and limitations) (522.6.201; 522.6.204)	N/A	
7.12	Provision of additional protection by 30mA RCD:		
7.12.1	For all socket-outlets of rating 32A or less, unless an exemption is permitted (411.3.3) *	Pass	
	For the supply of mobile equipment not exceeding 32A rating for use outdoors (411.3.3) *	Pass	
	For cables concealed in walls at a depth of less than 50mm (522.6.202, 522.6.203) *	Pass	
	For cables concealed in walls/partitions containing metal parts regardless of depth (522.6.203) *	N/A	
	For final circuits supplying luminaires within domestic (household) premises (411.3.4) *	Pass	
	* Note: Older installations designed prior to BS 7671:2018 may not have been provided with RCDs for addition protection.		
7.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	Pass	
7.14	Band II cables segregated/separated from Band I cables (528.1)	Pass	
7.15	Cables segregated/separated from non-electrical services (528.3)	Pass	
7 16			
7.16	Termination of cables at enclosures – identify/record numbers and locations of items inspected (Se 526):	ection	
	526):	Pass	
7.16.1	526):		
7.16.1 7.16.2	526): Connections under no undue strain (526.6)	Pass	
7.16.1 7.16.2 7.16.3	526): Connections under no undue strain (526.6) No basic insulation of a conductor visible outside enclosure (526.8)	Pass Pass	
7.16.1 7.16.2 7.16.3 7.16.4	526): Connections under no undue strain (526.6) No basic insulation of a conductor visible outside enclosure (526.8) Connections of live conductors adequately enclosed (526.5)	Pass Pass Pass	
7.16.1 7.16.2 7.16.3	Connections under no undue strain (526.6) No basic insulation of a conductor visible outside enclosure (526.8) Connections of live conductors adequately enclosed (526.5) Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5)	Pass Pass Pass Pass	
7.16.1 7.16.2 7.16.3 7.16.4 7.17	Connections under no undue strain (526.6) No basic insulation of a conductor visible outside enclosure (526.8) Connections of live conductors adequately enclosed (526.5) Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5) Condition of accessories including socket-outlets, switches and joint boxes (651.2)	Pass Pass Pass Pass Pass	
7.16.1 7.16.2 7.16.3 7.16.4 7.17 7.18	Connections under no undue strain (526.6) No basic insulation of a conductor visible outside enclosure (526.8) Connections of live conductors adequately enclosed (526.5) Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5) Condition of accessories including socket-outlets, switches and joint boxes (651.2) Suitability of accessories for external influences (512.2)	Pass Pass Pass Pass Pass Pass Pass	
7.16.1 7.16.2 7.16.3 7.16.4 7.17 7.18 7.19	Connections under no undue strain (526.6) No basic insulation of a conductor visible outside enclosure (526.8) Connections of live conductors adequately enclosed (526.5) Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5) Condition of accessories including socket-outlets, switches and joint boxes (651.2) Suitability of accessories for external influences (512.2) Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.3)	Pass Pass Pass Pass Pass Pass Pass	
7.16.1 7.16.2 7.16.3 7.16.4 7.17 7.18 7.19 8.0 8.1	Connections under no undue strain (526.6) No basic insulation of a conductor visible outside enclosure (526.8) Connections of live conductors adequately enclosed (526.5) Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5) Condition of accessories including socket-outlets, switches and joint boxes (651.2) Suitability of accessories for external influences (512.2) Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.3) ISOLATION AND SWITCHING	Pass Pass Pass Pass Pass Pass Pass	
7.16.1 7.16.2 7.16.3 7.16.4 7.17 7.18 7.19 8.0 8.1	Connections under no undue strain (526.6) No basic insulation of a conductor visible outside enclosure (526.8) Connections of live conductors adequately enclosed (526.5) Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5) Condition of accessories including socket-outlets, switches and joint boxes (651.2) Suitability of accessories for external influences (512.2) Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.3) ISOLATION AND SWITCHING Isolators (Sections 460; 537):	Pass Pass Pass Pass Pass Pass Pass	
7.16.1 7.16.2 7.16.3 7.16.4 7.17 7.18 7.19 8.0 8.1 8.1.1	Connections under no undue strain (526.6) No basic insulation of a conductor visible outside enclosure (526.8) Connections of live conductors adequately enclosed (526.5) Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5) Condition of accessories including socket-outlets, switches and joint boxes (651.2) Suitability of accessories for external influences (512.2) Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.3) ISOLATION AND SWITCHING Isolators (Sections 460; 537): Presence and condition of appropriate devices (Section 462; 537.2.7)	Pass Pass Pass Pass Pass Pass Pass Pass	
7.16.1 7.16.2 7.16.3 7.16.4 7.17 7.18 7.19 8.0 8.1 8.1.1 8.1.2	Connections under no undue strain (526.6) No basic insulation of a conductor visible outside enclosure (526.8) Connections of live conductors adequately enclosed (526.5) Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5) Condition of accessories including socket-outlets, switches and joint boxes (651.2) Suitability of accessories for external influences (512.2) Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.3) ISOLATION AND SWITCHING Isolators (Sections 460; 537): Presence and condition of appropriate devices (Section 462; 537.2.7) Acceptable location – state if local or remote from equipment in question (Section 462; 537.2.7)	Pass Pass Pass Pass Pass Pass Pass Pass	
7.16.1 7.16.2 7.16.3 7.16.4 7.17 7.18 7.19 8.0 8.1 8.1.1 8.1.2 8.1.3	Connections under no undue strain (526.6) No basic insulation of a conductor visible outside enclosure (526.8) Connections of live conductors adequately enclosed (526.5) Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5) Condition of accessories including socket-outlets, switches and joint boxes (651.2) Suitability of accessories for external influences (512.2) Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.3) ISOLATION AND SWITCHING Isolators (Sections 460; 537): Presence and condition of appropriate devices (Section 462; 537.2.7) Acceptable location – state if local or remote from equipment in question (Section 462; 537.2.7) Capable of being secured in the OFF position (462.3)	Pass Pass Pass Pass Pass Pass Pass Pass	
7.16.1 7.16.2 7.16.3 7.16.4 7.17 7.18 7.19 8.0 8.1 8.1.1 8.1.2 8.1.3 8.1.4	Connections under no undue strain (526.6) No basic insulation of a conductor visible outside enclosure (526.8) Connections of live conductors adequately enclosed (526.5) Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5) Condition of accessories including socket-outlets, switches and joint boxes (651.2) Suitability of accessories for external influences (512.2) Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.3) ISOLATION AND SWITCHING Isolators (Sections 460; 537): Presence and condition of appropriate devices (Section 462; 537.2.7) Acceptable location – state if local or remote from equipment in question (Section 462; 537.2.7) Capable of being secured in the OFF position (462.3) Correct operation verified (643.10)	Pass Pass Pass Pass Pass Pass Pass Pass	
7.16.1 7.16.2 7.16.3 7.16.4 7.17 7.18 7.19 8.0 8.1 8.1.1 8.1.2 8.1.3 8.1.4	Connections under no undue strain (526.6) No basic insulation of a conductor visible outside enclosure (526.8) Connections of live conductors adequately enclosed (526.5) Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5) Condition of accessories including socket-outlets, switches and joint boxes (651.2) Suitability of accessories for external influences (512.2) Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.3) ISOLATION AND SWITCHING Isolators (Sections 460; 537): Presence and condition of appropriate devices (Section 462; 537.2.7) Acceptable location – state if local or remote from equipment in question (Section 462; 537.2.7) Capable of being secured in the OFF position (462.3) Correct operation verified (643.10) Clearly identified by position and/or durable marking (537.2.6) Warning label posted in situations where live parts cannot be isolated by the operation of a single device	Pass Pass Pass Pass Pass Pass Pass Pass	
7.16.1 7.16.2 7.16.3 7.16.4 7.17 7.18 7.19 8.0 8.1 8.1.1 8.1.2 8.1.3 8.1.4 8.1.5	Connections under no undue strain (526.6) No basic insulation of a conductor visible outside enclosure (526.8) Connections of live conductors adequately enclosed (526.5) Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5) Condition of accessories including socket-outlets, switches and joint boxes (651.2) Suitability of accessories for external influences (512.2) Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.3) ISOLATION AND SWITCHING Isolators (Sections 460; 537): Presence and condition of appropriate devices (Section 462; 537.2.7) Acceptable location – state if local or remote from equipment in question (Section 462; 537.2.7) Capable of being secured in the OFF position (462.3) Correct operation verified (643.10) Clearly identified by position and/or durable marking (537.2.6) Warning label posted in situations where live parts cannot be isolated by the operation of a single device (514.11.1; 537.1.2)	Pass Pass Pass Pass Pass Pass Pass Pass	
7.16.1 7.16.2 7.16.3 7.16.4 7.17 7.18 7.19 8.0 8.1 8.1.1 8.1.2 8.1.3 8.1.4 8.1.5 8.1.6	Connections under no undue strain (526.6) No basic insulation of a conductor visible outside enclosure (526.8) Connections of live conductors adequately enclosed (526.5) Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5) Condition of accessories including socket-outlets, switches and joint boxes (651.2) Suitability of accessories for external influences (512.2) Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.3) ISOLATION AND SWITCHING Isolators (Sections 460; 537): Presence and condition of appropriate devices (Section 462; 537.2.7) Acceptable location – state if local or remote from equipment in question (Section 462; 537.2.7) Capable of being secured in the OFF position (462.3) Correct operation verified (643.10) Clearly identified by position and/or durable marking (537.2.6) Warning label posted in situations where live parts cannot be isolated by the operation of a single device (514.11.1; 537.1.2) Switching off for mechanical maintenance (Section 464; 537.3.2):	Pass Pass Pass Pass Pass Pass Pass Pass	
7.16.1 7.16.2 7.16.3 7.16.4 7.17 7.18 7.19 8.0 8.1 8.1.1 8.1.2 8.1.3 8.1.4 8.1.5 8.1.6 8.2 8.2.1	Connections under no undue strain (526.6) No basic insulation of a conductor visible outside enclosure (526.8) Connections of live conductors adequately enclosed (526.5) Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5) Condition of accessories including socket-outlets, switches and joint boxes (651.2) Suitability of accessories for external influences (512.2) Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.3) ISOLATION AND SWITCHING Isolators (Sections 460; 537): Presence and condition of appropriate devices (Section 462; 537.2.7) Acceptable location – state if local or remote from equipment in question (Section 462; 537.2.7) Capable of being secured in the OFF position (462.3) Correct operation verified (643.10) Clearly identified by position and/or durable marking (537.2.6) Warning label posted in situations where live parts cannot be isolated by the operation of a single device (514.11.1; 537.1.2) Switching off for mechanical maintenance (Section 464; 537.3.2): Presence and condition of appropriate devices (464.1; 537.3.2)	Pass Pass Pass Pass Pass Pass Pass Pass	
7.16.1 7.16.2 7.16.3 7.16.4 7.17 7.18 7.19 8.0 8.1 8.1.1 8.1.2 8.1.3 8.1.4 8.1.5 8.1.6 8.2	Connections under no undue strain (526.6) No basic insulation of a conductor visible outside enclosure (526.8) Connections of live conductors adequately enclosed (526.5) Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5) Condition of accessories including socket-outlets, switches and joint boxes (651.2) Suitability of accessories for external influences (512.2) Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.3) ISOLATION AND SWITCHING Isolators (Sections 460; 537): Presence and condition of appropriate devices (Section 462; 537.2.7) Acceptable location – state if local or remote from equipment in question (Section 462; 537.2.7) Capable of being secured in the OFF position (462.3) Correct operation verified (643.10) Clearly identified by position and/or durable marking (537.2.6) Warning label posted in situations where live parts cannot be isolated by the operation of a single device (514.11.1; 537.1.2) Switching off for mechanical maintenance (Section 464; 537.3.2): Presence and condition of appropriate devices (464.1; 537.3.2) Acceptable location – state if local or remote from equipment in question (537.3.2.4)	Pass Pass Pass Pass Pass Pass Pass Pass	
7.16.1 7.16.2 7.16.3 7.16.4 7.17 7.18 7.19 8.0 8.1 8.1.1 8.1.2 8.1.3 8.1.4 8.1.5 8.1.6 8.2 8.2.1 8.2.2	Connections under no undue strain (526.6) No basic insulation of a conductor visible outside enclosure (526.8) Connections of live conductors adequately enclosed (526.5) Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5) Condition of accessories including socket-outlets, switches and joint boxes (651.2) Suitability of accessories for external influences (512.2) Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.3) ISOLATION AND SWITCHING Isolators (Sections 460; 537): Presence and condition of appropriate devices (Section 462; 537.2.7) Acceptable location – state if local or remote from equipment in question (Section 462; 537.2.7) Capable of being secured in the OFF position (462.3) Correct operation verified (643.10) Clearly identified by position and/or durable marking (537.2.6) Warning label posted in situations where live parts cannot be isolated by the operation of a single device (514.11.1; 537.1.2) Switching off for mechanical maintenance (Section 464; 537.3.2): Presence and condition of appropriate devices (464.1; 537.3.2) Acceptable location – state if local or remote from equipment in question (537.3.2.4) Capable of being secured in the OFF position (462.3)	Pass Pass Pass Pass Pass Pass Pass Pass	
7.16.1 7.16.2 7.16.3 7.16.4 7.17 7.18 7.19 8.0 8.1 8.1.1 8.1.2 8.1.3 8.1.4 8.1.5 8.1.6 8.2 8.2.1 8.2.2	Connections under no undue strain (526.6) No basic insulation of a conductor visible outside enclosure (526.8) Connections of live conductors adequately enclosed (526.5) Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5) Condition of accessories including socket-outlets, switches and joint boxes (651.2) Suitability of accessories for external influences (512.2) Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.3) ISOLATION AND SWITCHING Isolators (Sections 460; 537): Presence and condition of appropriate devices (Section 462; 537.2.7) Acceptable location – state if local or remote from equipment in question (Section 462; 537.2.7) Capable of being secured in the OFF position (462.3) Correct operation verified (643.10) Clearly identified by position and/or durable marking (537.2.6) Warning label posted in situations where live parts cannot be isolated by the operation of a single device (514.11.1; 537.1.2) Switching off for mechanical maintenance (Section 464; 537.3.2): Presence and condition of appropriate devices (464.1; 537.3.2) Acceptable location – state if local or remote from equipment in question (537.3.2.4) Capable of being secured in the OFF position (462.3) Correct operation verified (643.10) Clearly identified by position and/or durable marking (537.3.2.4)	Pass Pass Pass Pass Pass Pass Pass Pass	

Ref: 23650240 - Page: 6 of 10

	NSPECTION SCHEDULE (CONTINUED)	
/ Item	Description	Outcome
8.3	Emergency switching/stopping (Section 465; 537.3.3):	
8.3.1	Presence and condition of appropriate devices (Section 465; 537.3.3; 537.4)	N/A
8.3.2	Readily accessible for operation where danger might occur (537.3.3.6)	N/A
8.3.3	Correct operation verified (643.10)	N/A
8.3.4	Clearly identified by position and/or durable marking (537.3.3.6)	N/A
8.4	Functional switching (Section 463; 537.3.1):	
8.4.1	Presence and condition of appropriate devices (537.3.1.1; 537.3.1.2)	Pass
8.4.2	Correct operation verified (537.3.1.1; 537.3.1.2)	Pass
9.0	CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED)	
9.1	Condition of equipment in terms of IP rating etc (416.2)	Pass
9.2	Equipment does not constitute a fire hazard (Section 421)	Pass
9.3	Enclosure not damaged/deteriorated so as to impair safety (134.1.1; 416.2; 512.2)	Pass
9.4	Suitability for the environment and external influences (512.2)	Pass
9.5	Security of fixing (134.1.1)	Pass
9.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire: List number and location of luminaires inspected (separate page) (527.2)	Pass
9.7	Recessed luminaires (downlighters):	
9.7.1	Correct type of lamps fitted (559.3.1)	Pass
9.7.2	Installed to minimise build-up of heat by use of 'fire rated' fittings, insulation displacement box or similar (421.1.2)	Pass
9.7.3	No signs of overheating to surrounding building fabric (559.4.1)	Pass
9.7.4	No signs of overheating to conductors/terminations (526.1)	Pass
10.0	LOCATION(S) CONTAINING A BATH OR SHOWER	
10.1	Additional protection for all low voltage (LV) circuits by RCD not exceeding 30mA (701.411.3.3)	N/A
10.2	Where used as a protective measure, requirements for SELV or PELV met (701.414.4.5)	N/A
10.3	Shaver supply units comply with BS EN 61558-2-5 formerly BS 3535 (701.512.3)	N/A
10.4	Presence of supplementary bonding conductors, unless not required by BS 7671:2018 (701.415.2)	N/A
10.5	Low voltage (e.g. 230 V) socket-outlets sited at least 2.5m from zone 1 (701.512.3)	N/A
10.6	Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2)	N/A
10.7	Suitability of accessories and controlgear etc. for a particular zone (701.512.3)	N/A
10.8	Suitability of current-using equipment for particular position within the location (701.55)	N/A
11.0	OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS List all other special installation or locations present, if any. (Record separately the results of particular inspection)	ons)
11.1	N/A	N/A
11.2	N/A	N/A
11.3	N/A	N/A
11.4	N/A	N/A
11.5	N/A	N/A
12.0	PROSUMER'S LOW VOLTAGE ELECTRICAL INSTALLATION(S) Where the installation includes additional requirements and recommendations relating to Chapter 82, additional items should be added to the checklist below.	inspection
12.1	N/A	N/A
12.2	N/A	N/A
12.3	N/A	N/A
12.4	N/A	N/A
12.5	N/A	N/A
Inspect	ted hv:	
Name:		/07/2024
оитсом		
Acceptal condition		ot cable N/A

D	ISTRIBUTION	ВОА	RD DE	TAI	LS																											
DB re	eference:		Switch	Fuse	1				Loc	cation:		Е	lect	rical	Cupboa	ard				Supp	lied	from	om: Origin									
Distribu	ution circuit OCPD:	BS (EN):				13	361				٦	уре:	:	2	Ra	itin	g/Set	tting	g:	100	Α		No	o of p	hases	: [3				
SPD De	etails: Types:	T1	N/A	T2	N/A	Т	3	N/A	N	/A 🗸					indicator						N/A	4										
Confirn	nation of supply pol									sequenc	e.	r	N/A	ilctio	ilality lile	uicac	Oi j	prese	1111)		•		Zs a	t DB	. [).12 <u>د</u>)	ı	pf at	DB:	1.9	9 kA
	CHEDULE OF C		ITT DE	TAT									•// `													J						
<u> </u>	CHEDULE OF C	JIKCC	JII DE	IAI	LS A		CUIT			ULIS				***************************************										7	TEST R	ESULT	DETAIL	s				
					Cond	luctor d	etails		(s)	Overcur	rent p	rotecti	ve dev	/ice		RC	:D				Con	tinuity	(Ω)		Insul	ation res	istance		Zs	RO	CD	AFDD
					P			nber size	time 37671											Ring	final c	rcuit	R ₁ -	+R ₂ R ₂								LO CO
Circuit number	Circuit desc	ription		Type of wiring	Reference method	Number of points served	Live (mm ²)	cpc (mm ²)	Max disconnect t permitted by BS	BS (EN)	Type	Rating (A)	Breaking capacity (kA)	Maximum permitted Zs (Ω)	BS (EN)		Туре	Rated operating current (mA)	Rating (A)	r ₁ (line)	rn (neutral)	r2 (cpc)	R1+R2	R2	Test voltage (V)	Live - Live (M Ω)	Live - Earth (MΩ)	Polarity (tick)	Maximum measured (Ω)	Disconnection time (ms)	Test button operation (tick)	Manual test button operation (tick)
1	DB Flat A First Floor			Α	С	1	16	10	5	1361	2	60		0.67		N		N/A N	I/A				0.05		500	100	100	✓	0.14		N/A	
CODES TYPE WIR	OF insulated/shea		Thermop cables metallic	olastic s in	-	(C ermople cables etallic	in	it	Thermopl cables metallic tru	in) !	(E ermopl cables etallic t				plastic cables			rmose	G H mosetting Mineral /A cables insulated cables					o - Other N/A					
1 /	ETAILS OF TES							orc) -																								
V	ils of test instrumer Inctional:	its use	u (Serial				umbe	ers):	Ir	sulation	resis	stanc	e:										Cor	ntinu	ity:							
Multi-functional: 4299108 Earth electrode resistance:								arth fault				nce:									RCI		•,									
TESTED BY							on:]	Elect	ricia	an			Sig	natu	re:					Alek in	mes				Dat	e:	12	/07/	'202 ₄	4

D	ISTRIBUTION	BOAI	RD DE	TAI	LS																										
/DB r	eference:	DE	3 Ground	d Flo	or Fla	at			Loc	cation: G	rour	nd Fl	oor	Flat E	lectrica	l Cup	boa	rd	Sup	olied	from £	witc	h Fu	ise 1	(Grou	ınd Fl	oor	Elect	rical	Cup	board
Distrib	ution circuit OCPD:	BS (E	EN):				13	861				٦	ype		2	Rati	ng/S	ettin	ıg:	100) A		No	o of p	hases	:	1				
SPD De	etails: Types:	T1 [N/A	T2	N/A	T	3	N/A	N	/A √	•				ndicator ality ind					N/A	4										
Confirm	nation of supply pol	arity	\checkmark		Co	nfirn	nation	n of p	phase sequence N/A										Zs a	t DB:	: ().14 g	2	I	pf at	DB:	1.0	6 kA			
/s	CHEDULE OF C	CIRCU	IT DE	TAI	LS A	AND	TE	ST I	RES	ULTS																					
						CIR	CUIT I	DETAI	LS														1	EST R	ESULT	DETAIL	s				
Conductor details										Overcuri	rent pi	rotecti	ve de	/ice		RCD				Con	tinuity	(Ω)		Insula	ation res	sistance		Zs	RC	D	AFDD
Circuit number	Circuit desc	ription		Type of wiring	Reference method	Number of points served	and	cbc (mm ²)	Max disconnect time permitted by BS7671	BS (EN)	Туре	Rating (A)	Breaking capacity (kA)	Maximum permitted Zs (Ω)	BS (EN)	Туре	Rated operating current (mA)	Rating (A)	r1 (line)	rn (neutral)	ircuit (cbc)	R1+R2	+R2 R2	Test voltage (V)	Live - Live (MΩ)	Live - Earth (MΩ)	Polarity (tick)	Maximum measured (Ω)	Disconnection time (ms)	Test button operation (tick)	Manual test button operation (tick)
Main S	witch																														
RCD 1																															
1	Hob 1			Α	С	1	6	2.5	0.4	60898	В	32	6	1.37	61008	AC	30	63				0.2		500	100	100	✓	0.36	16	✓	N/A
2	Sockets Front			Α	С	14	2.5	1.5	0.4	60898	В	10	6	4.37	61008	AC	30	63	0.6	0.6	1.0	0.4		500	100	100	✓	0.59	16	✓	N/A
3	Ovens			Α	С	2	2.5	1.5	0.4	60898	В	20	6	2.19	61008	AC	30	63				0.3		500	100	100	✓	0.46	16	✓	N/A
4	Lights Rear			Α	С	10	1.5	1.0	0.4	60898	В	6	6	7.28	61008	AC	30	63				1.1		500	100	100	✓	1.27	16	✓	N/A
5	Spare																														
6	Spare																	-													
7	Spare																														
RCD 2																															
CODES TYPE WIR	OF insulated/shea		Thermop cables metallic	olastic s in			cables	in	it	Thermople cables metallic tru	in	ı	(E ermopla cables in etallic tr	n	Thern /SW	F noplas A cabl			G ermoset WA cab		in	Min sulate		S			0 - Oth N/A			
	ETAILS OF TE	NT TR				1																									=
-	ils of test instrumer					set n	umbe	ers):																							
Multi-fu	unctional:			429	9910	8(II	nsulation	resis	stanc	e:									Cor	ntinu	ity:							
Earth e	electrode resistance	:							E	arth fault	loop	imp	edar	nce:								RCI	D:								
<u></u>	ESTED BY																														
Nam	Name: Alun Davies Position:								Electrician Signature:										Marie: 12/07/2024							4					
his for	is form is based on the model shown in Appendix 6 of BS 76								2018	+A2:202	2.															Ref: 2	3650	0240	- Pag	e: 9	of 10

SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS Location: Ground Floor Flat Electrical Cupboard Supplied from Switch Fuse 1 (Ground Floor Electrical Cupboard) **DB Ground Floor Flat** DB reference: **CIRCUIT DETAILS TEST RESULT DETAILS** Conductor details Overcurrent protective device **RCD** Continuity (Ω) Insulation resistance Z_{S} RCD AFDD Max disconnect time permitted by BS7671 Number R_1+R_2 Ring final circuit Reference method and size or R₂ Live - Earth (M Ω) Manual test butt operation (tick) Live - Live (MΩ) Test voltage (V) Circuit number Number of points served (G) Circuit description Type of wiring Rated operating current (mA) Polarity (tick) Live (mm²) r_n (neutral) cpc (mm²) Maximum measured (Rating (A) Rating (A) (line) (EN) BS (EN) r2 (cpc) $R_{1}+R_{2}$ Туре 8 Hob 2 Α С 1 6 2.5 0.4 60898 В 32 6 1.37 AC 30 63 0.2 100 100 0.34 15 ✓ N/A 61008 500 Sockets Kitchen 1.5 0.4 0.4 0.7 0.3 N/A 9 Α C 10 2.5 60898 В 10 6 4.37 61008 AC 30 63 0.4 500 100 100 0.48 15 10 Sockets Rear Α C 19 2.5 1.5 0.4 60898 В 10 6 4.37 61008 AC 30 63 0.9 0.9 1.5 0.6 500 100 100 0.77 15 **√** N/A TV Amplifier Socket C 1.5 0.4 60898 20 2.19 61008 AC 30 63 0.05 500 100 0.21 15 N/A 11 Α 1 2.5 В 6 100 12 **Lights Front** Α C 11 1.5 1.0 0.4 60898 В 6 6 7.28 61008 AC 30 63 1.1 500 100 100 1.21 15 **√** N/A N/A 13 Lights Hallway Including Emergency Α C 1.5 1.0 0.4 60898 В 6 6 7.28 61008 AC 30 63 0.5 500 100 100 0.67 15 Units 14 Spare В O - Other CODES FOR Thermoplastic Thermoplastic Thermoplastic Thermoplastic Thermoplastic Thermoplastic Thermosetting Mineral TYPE OF insulated/sheathed N/A cables in cables in cables in cables in /SWA cables /SWA cables insulated cables nonmetallic trunking WIRING metallic conduit nonmetallic conduit metallic trunking

ELECTRICAL INSTALLATION CONDITION REPORT GUIDANCE FOR RECIPIENTS

(to be appended to the Report)

This Report is an important and valuable document which should be retained for future reference.

- 1. The purpose of this Report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see Section 5). The Report should identify any damage, deterioration, defects and/or conditions which may give rise to danger (see Section 7).
- 2. This Report is only valid if accompanied by the Inspection Schedule(s) and the Schedule(s) of Circuit Details and Test Results
- 3. The person ordering the Report should have received the 'original' Report and the inspector should have retained a duplicate.
- 4. The original Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner/occupier with details of the condition of the electrical installation at the time the Report was issued.
- 5. Section 4 (Extent and Limitations) should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.
- 6. Some operational limitations such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in Section 4.
- 7. For items classified in Section 7 as CI (Danger present), the safety of those using the installation is at risk, and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work immediately.
- 8. For items classified in Section 7 as C2 (Potentially dangerous), the safety of those using the installation at risk and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.
- 9. Where it has been stated in Section 7 that an observation requires further investigation (code FI) the inspection has revealed an apparent deficiency which may result in a code CI or C2, and could not, due to the extent or limitations of the inspection, be fully identified. Such observations should be investigated without delay. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see Section 7).
- 10. For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The recommended date by which the next inspection is due is stated in Section 7 of the Report under Recommendations.
- 11. Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. For safety reasons it is important that this instruction is followed.
- 12. Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should. be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions shall be followed with respect to test button operation.
- 13. Where the installation includes a surge protective device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice. For safety reasons it is important that this instruction is followed.
- 14. Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.