## Landlord Home Owner Gas Safety Record



This inspection is for gas safety purposes only to comply with the Gas Safety (Installation and Use) Regulations. Flues have been inspected and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and the lining has NOT been carried out.

Registered business					Job address L			Landl	ord/age	nt		Certificate information		
Gas safe ID 532935 Energy Systems (SW) Ltd 4 Cleaves Close Thorverton  K P P D				Kilmorie Mews, Flat 1 Pennsylvania Road Exeter Devon EX4 6DG			Oak Pa Huxha Exeter Devon EX5 41	J V Pengelly Building Contractors Oak Park Huxham Exeter Devon EX5 4EL +44 01392 841309			Date 19/07/2024 Number 2463 Next inspection due 19/07/2025			
No	Location Appliance type		Make/model			Flue type	Landlords appliance		liance ?	Combustion analyser reading	Operating pressured or heat input	re Safety devic	e(s) ation	
1	Kitchen	Combina	tion Boiler	Baxi/Duo	-tec 2 40 GA		BF	Yes	Yes		Ok	22	Yes	
No	satisfactory termination		dition of the flue & Flue performance checks		Appliance serviced		Applia safe to	o use alarm fitted?		Is CO alarm in date? Testing of CO alarm		arm		
1	N/A		Yes			Pass	Ye	2S	Yes		Yes	Yes	Yes	
No	Defect(s) identified			Remedial action taken W			Wa	Warning/Advice notice issued		Number of appliances tested				
										Gas installation pipework (visual inspection) satisfactory?  Gas tightness test satisfactory?				
											Emergency contro			
														Yes
												Yes		
Engineer information Engineer name: Jon Day Gas safe card ID: 4141406 Signature:				Received by information  Name: J V Pengelly Building Contractors Received by: Customer  Signature:					Comm	ents				

Analyser readings	App 1	App 2	App 3	App 4
Working pressure (at meter)	21 mbar			
Working appliance pressure	21 mbar			
Co parts per million	83			
Percentage co2	8.53			
Percentage oxygen	6			
Co/Co2 ratio	0.0010			
Gross flue gas temperature	54			
Gas rate (if applicable)				