## Landlord Home Owner Gas Safety Record



This inspection is for gas safety purposes only to comply with the Gas Safety (Installation and Use) Regulations. Flues have been inspected and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and the lining has NOT been carried out.

Registered business					Job address La			Landlord/agent				Certificate infor	Certificate information		
Energy Systems (SW) Ltd 4 Cleaves Close				Molly Hayes, Apartment 2 Exeter Devon EX4 4DQ E			J V Pengelly Building Contractors Oak Park Huxham Exeter Devon EX5 4EL +44 01392 841309			ntractors	Date 23/07/2025 Number 2837 Next inspection due 23/07/2026				
No	Location Appliance type		ce type	Make/model			Flue Landlords			Applia insp?	ance	Combustion analyser reading	Operating pressure Safety device correct oper		ce(s) ration
1	Kitchen System E		3oiler Keston/S		System 30		NA	Yes		Yes 0		0.0010	20 mb	Yes	
No	No Ventilation provision satisfactory		Visual cond termination				A	Appliance serviced		Appliance safe to use		Approved CO alarm fitted?	Is CO alarm in date? Testing of CO alarm satisfactory		larm
1	N/A	Yes		Pass		Y	Yes		Yes		Yes	Yes Yes			
No	Dofost(s) identifi	ad			Domodial ac	tion taken			Warı	ning/Ad	vice	Number of appliance	l ces tested		1
	(0,								notice issued		Gas installation pipework (visual inspection) satisfactory?				
1	Low water pressure switch faulty N				needs new as	Needs new asap No				INO		Gas tightness test satisfactory?			
												Emergency control valve accessible?			
									Protective equipotential bonding satisfactory?						
	P					Be sained by information					Audible carbon monoxide alarm fitted? Yes				
-						eived by information					Comments  Needs now low water pressure switch and now AAV				
Engineer name: Jon Day Gas safe card ID: 4141406						Name: J V Pengelly Building Contractors Received by: Customer					Needs new low water pressure switch and new AAV				
Sign	Signature:				Signature:	Signature:									

Analyser readings	App 1	App 2	App 3	App 4
Working pressure (at meter)	20 mb mbar			
Working appliance pressure	20 mb mbar			
Co parts per million	90			
Percentage co2	9.24			
Percentage oxygen	4.7			
Co/Co2 ratio	0.0010			
Gross flue gas temperature	55			
Gas rate (if applicable)				