

This inspection is for gas safety purposes only to comply with the Gas Safety (Installation and Use) Regulations. Flues have been inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and lining has NOT been carried out.

REGISTERED BUSINESS DETAILS

Reg No: 2327717
Company: Ecolohant
Address: East Canada Park
Postcode: L90 1Q6
Tel: 07879502766

INSPECTION/INSTALLATION ADDRESS

Name & Title: S3 Alderson Ltd.
Address: L'hoer
Postcode: L45 2HL
Tel:

LANDLORD (OR AGENT) NAME & ADDRESS (if applicable)

Name & Title: Gordon Waples
Address: Waples
Postcode: W41
Tel:

Number of appliances tested: _____

APPLIANCE DETAILS

Location	Make and Model	Type	Flue Type Of/RS/FL	Operating pressure in heat input (kW/h or Btu/h)	Safety device(s) correct operation Yes/No/N/A	Spillage test Pass/Fail/N/A	Smoke pellet flow test Pass/Fail/N/A	Initial combustion analyser reading	Final combustion analyser reading	Satisfactory termination Yes/No/N/A	Flue visual condition Pass/Fail/N/A	Adequate ventilation Yes/No	Landlord's appliance Yes/No/N/A	Inspected Yes/No	Appliance Visual Check Yes/No	Appliance serviced Yes/No	Appliance Safe to Use Yes/No
1 Kitchen	MAIR 24NE	Gas	RS	22.8	Yes	N/A	N/A	0.0002	0.0007	Y07	Pass	Yes	Yes	Yes	Yes	Yes	Yes
2																	
3																	
4																	
5																	

For appliances not owned by the landlord the recorded 'Appliance Safe to Use' response is based on a visual check for obvious defects only

Gas Installation Satisfactory Visual Yes ☒ No ☐ Emergency Control Yes ☒ No ☐ Accessible: Yes ☒ No ☐ Satisfactory Gas Tightness Test: Yes ☒ No ☐ Equipmental Bonding Satisfactory: Yes ☒ No ☐

GIVE DETAILS OF ANY FAULTS

RECTIFICATION WORK CARRIED OUT

WARNING * WARNING TAG or
NOTICE ISSUED Yes/No/N/A LABEL FIXED Yes/No/N/A

Approved Audible CO Alarms Fitted & Located Correctly** Yes ☒ No ☐ N/A ☐ Are CO Alarms in Date: Yes ☒ No ☐ N/A ☐ Testing of CO Alarms Satisfactory: Yes ☒ No ☐ N/A ☐ Smoke/Heat Alarms Located & Fitted correctly** Yes ☒ No ☐ N/A ☐

OTHER COMMENTS OR OBSERVATIONS

NEXT GAS
SAFETY
CHECK DUE
BEFORE:
19/12/26

ISSUED BY (GAS ENGINEER)

Print Name: S. L. 2020 Signed: [Signature]
Licence No: 5698112 Issue Date: 08/12/25

RECEIVED BY

Received By: [Signature] Tenant/Agent/Landlord/Home Owner
Signed: [Signature] Print Name: [Signature]
No one present at time of visit ☒