

This inspection is for gas safety purposes only to comply with the Gas Safety (Installation and Use) Regulations. Flues have been inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and lining has NOT been carried out.

REGISTERED BUSINESS DETAILS

Reg No: 232717
Company: Eitehead
Address: East Carver's Beck
Postcode: 190 1805
Tel: 01572502766

INSPECTION/INSTALLATION ADDRESS

Name & Title:
Address: 78 Alderson Rd
Postcode: HS 14N
Tel:

LANDLORD (OR AGENT) NAME & ADDRESS (if applicable)

Name & Title: Landlord Properties
Address: Mill Lane
Postcode: HU1 2AP
Tel:

Number of appliances tested: 1

APPLIANCE DETAILS

Location	Make and Model	Type	Fue Type OF/RS/FL	Operating pressure in bar or heat input kW/h or Btu/h	Safety device(s) correct operation Yes/No/NA	Spillage test Pass/Fail/NA	Smoke pellet flue flow test Pass/Fail/NA	Initial combustion analyser reading	Final combustion analyser reading	Satisfactory termination Yes/No/NA	Fue Visual condition Pass/Fail/NA	Adequate ventilation Yes/No	Landlord's appliance Yes/No/NA	Inspected Visual Yes/No	Appliance Check Yes/No	Appliance serviced Yes/No	Appliance Safe to Use Yes/No
1 Bathroom	106RL 106RL/106RL	BA	AS	22.8	Yes	NA	NA	0.002/0.0008	Yes	Pass	Yes	Yes	Yes	Yes	Yes	Yes	Yes
2																	
3																	
4																	
5																	

For appliances not owned by the landlord the recorded 'Appliance Safe to Use' response is based on a visual check for obvious defects only

Gas Installation
Satisfactory Visual Inspection:Yes ☒ No ☐Emergency Control
Accessible:Yes ☒ No ☐Satisfactory Gas
Tightness Test:Yes ☒ No ☐Equipotential
Bonding Satisfactory:Yes ☒ No ☐

GIVE DETAILS OF ANY FAULTS

RECTIFICATION WORK CARRIED OUT

1	2	3	4	5	WARNING NOTICE ISSUED Yes/No/NA	* WARNING TAG or LABEL FIXED Yes/No/NA

Approved Audible CO Alarms
Fitted & Located Correctly**:Yes ☒ No ☐ N/AAre CO
Alarms in Date:Yes ☒ No ☐ N/ATesting of CO
Alarms Satisfactory:Yes ☒ No ☐ N/ASmoke/Heat Alarms
Located & Fitted correctly**:Yes ☒ No ☐ N/A

OTHER COMMENTS OR OBSERVATIONS

**NEXT GAS
SAFETY
CHECK DUE
BEFORE:**

191218

ISSUED BY (GAS ENGINEER)

Print Name:

Signed: 18/12/2018

Licence No: 569812

Issue Date: 18/12/2018

RECEIVED BY

Print Name:

Signed:

Received By:

Tenant/Agent/Landlord/Home Owner

No one present
at time of visit ☒