

Landlord Gas Safety Record

Cert. No. 521

Gas and heating specialists

Safety Inspection and reporting carried out in accordance with the Gas Safety (Installation and Use) Regulations 1998 section 26(9) and the Gas Industry Unsafe Situations Procedure.

								,											
Company / I	Job Address							Customer / L	andlord										
Engineer	Steven Balla	rd			Name							Name							
Company	Ballards gas services ltd				Address 68							Company							
Address 201					D	erby Road	b				Address	mill house							
	Sileby Road					Lo	Loughborough						Lugg Bridge Mill						
	Barrow Upon Soar				Leicestershire								Worcester Road						
	Leicestershire				Post Code	e Li	LE11 5BX						Hereford						
Post Code	LE12 8LP	-			Tel. No					Post Code	HR1 3NA								
Tel No.											Tel. No								
	as Safe Reg 527987																		
ID Card No.																			
ib card No.																			
Appliance D	etails						Inspec	ction Details											
Location	п Ар	opliance Type	Make	Mode	el	Flue Type	Landlord's Appliance	Appliance Inspected	Operating Pressure (mbar)	Heat Input (kW/h)	High Combusti Reading	on Low Combustion Reading	Safety device(s) Ventilation Provision	Visual condition of flue and	Flue Performance	Appliance Serviced	Appliance safe to use	
							Appliance		(IIIbai)			CO2 Ratio CO CO		satisfactory	termination satisfactory	test	Serviceu	to use	
1 100					20	D.C.		V/	21.5	20.25	ppm	% ppm %	•					.,	
1 Kitche	n Comb	ination Boiler	Ideal	Logic M	ax 30	RS	Yes	Yes	21.5	29.25	0007 101	9.0 0001 14 8.0	6 Yes	Yes	Yes	Pass	No	Yes	
2																			
3																			
4																			
5																			
6									l abala a	nd Marcina Na	ties les usel						_		
Defects / Identified								Labels and Warning Notice Issued			CO Alarm(s)				(S				
1										NA		CO Alarm(s) fit	tted	Yes	Smoke	Alarm(s) fit	ted	NA	
2																			
3												CO Alarm(s) to		Pass		Alarm(s) te	sted	NA	
4												and Satisfacto	ту		and Sai	isfactory			
5 6															Water	quality/leve	l of inhihito	r	
0															accepta		i or iriiinbicc	" NA	
												<u> </u>							
Emergency Co	ntrol Accessib	le Yes Gas	Tightness Satisfactory Yes	S	Com	ments													
Gas Installation	n Dinawark Vis	rual Inspection	Satisfactory Yes																
Gas ilistaliation	ii ripework vis	sual inspection	Satisfactory Tes																
Equipotent	tial Bonding Y	es																	
NEXT INSPEC	TION DUE RE	FORF	15-May-2026																
NEXT INST EC	THOM DOL DE	OIL																	
Signatures																			
Issued by:	Signed 10 F					Received Signed						Date							
,	J	Balle	ul		by:	5								1ay-2025					
		7200	·																
Print Name	9	Steven Ballard		F	Print Name														